



- NOTES:
- △ 1. THE CAPACITORS ARE ENERGY STORAGE FOR EPO WHEN NO OTHER SOURCE IS AVAILABLE
 $C1 = B41456-B7339-M = 33000\mu F (202-0333)$, $C2 = B41456-B7339-M = 33000\mu F (202-0333)$
 - △ 2. 15 CONDUCTOR IS SHIELDED TWISTED PAIR PROVIDED BY APC
 3. - - - - - = EPO WIRING OPTIONAL.
 - △ 4. IF BATTERY CABINET FUSES ARE NOT PRESENT, THE TERMINALS WILL HAVE TO BE FITTED WITH JUMPERS.
 - △ 5. FOR BOARD PART NUMBERS CHECK THE LATEST REVISIONS.
 - △ 6. INSTALLATION MUST COMPLY WITH NATIONAL AND LOCAL ELECTRICAL REGULATIONS.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF AMERICAN POWER CONVERSION AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM APC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

TITLE: SYMMETRA MW
 400V, 3PH, 2x600kW N+1
 SYSTEM WIRING DIAGRAM

PROJECT: SUBMITTAL DRAWINGS SHEET 1 OF 1

DWG NO: SYMF600K600HR2-WD

DRAWN: BALAMURUGAN
 CHECKED: B.H.NIELSEN
 ENGINEER: CLARSEN / S.WACH

27/03/07
 27/03/07
 27/03/07

REV: 4

PROJECTION

APC
 AMERICAN POWER CONVERSION
 132 FAIRGROUNDS RD
 WEST KINGSTON, RI 02892





B&A Services bv

Vleugelboot 30 - 3991 CL Houten

Telefoon (030) 657 94 86 - fax (030) 657 94 81

info@baservices.nl - www.baservices.nl

B&A Services
Noodstroomsystemen